

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE

LISTING No. 7300-0694:228 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Fire Control Instruments, 301 2nd Avenue, Waltham, MA 02451
Contact: Anthony J. Shalna (781) 370-4194

DESIGN: Models AOM-MUX and AOM-TEL control modules. Unit is intended to be installed in a standard 4" square junction box. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 16-32 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessories for use with separately listed compatible fire alarm control units.

XLF: 7300-1209:198



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 11, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO**, Supervising Deputy
Program Manager